



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-11

Lab# 000

Customer

Facility Name: Camp Deer Creek
Address: 109 Eisele Road
Cheswick, PA 15024

Matrix: Recreational Water

Source Type: Creek

Sample Collection

Date: 6/16/26
Time: 3:00 PM
Method: Grab

Sample Final Analysis

Date: 6/18/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/26	10:00 AM	SL	SM 9222G
Total coliforms:	5/100mls	2/100mls	6/17/26	10:00 AM	SL	SM 9222B
Standard plate count:	570/ml	200/ml	6/16/26	4:30 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/16/26	3:00 PM	SH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/16/26	3:00 PM	SH	DPD
Turbidity:	2 NTU	1 - 2 NTU	6/16/26	3:00 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor