



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-11

Lab# 2087

Customer

Facility Name: Chanticleer Condominiums
Address: 53 Highland Rd.
Bethel Park, PA 15102

Sample Collection

Date: 6/16/26
Time: 9:50 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 6/18/26
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/26	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/26	11:00 AM	AH	SM 9222B
Standard plate count:	570/ml	200/ml	6/16/26	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/16/26	9:50 AM	AHV	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/16/26	9:50 AM	AHV	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/26	9:50 AM	AHV	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)