



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2800

Customer

Facility Name: Midland Boro
Address: 936 Midland Ave.
Midland, PA 15059

Sample Collection

Date: 6/17/26
Time: 12:00 PM
Method: Grab

Matrix: Recreational Water
Source Type: Small Pool

Sample Final Analysis

Date: 6/19/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/26	10:00 AM	AH	SM 9222B
Standard plate count:	570/ml	200/ml	6/17/26	6:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	6/17/26	12:00 PM	JB	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/17/26	12:00 PM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/26	12:00 PM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor