



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2395

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Parkside Estates*
Address: *202 Ketchum Court*
 Cannonsburg, PA 15317

Sample Collection

Date: 6/16/26
Time: 3:26 PM
Method: Grab

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: 6/18/26
Time: 12:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/26	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/26	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/16/26	3:26 PM	JMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/26	3:26 PM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/26	3:26 PM	JMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor