



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2519

Customer

Facility Name: Sunridge
Address: 1 Sunridge Dr.
Champion, PA 15622

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 6/15/26
Time: 11:08 AM
Method: Grab

Sample Final Analysis

Date: 6/17/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/16/26	10:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/16/26	10:00 AM	AS	SM 9222B
Standard plate count:	5/ml	200/ml	6/15/26	4:30 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/16/26	12:30 PM	AS	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/15/26	11:08 AM	JC	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/15/26	11:08 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/15/26	11:08 AM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)