



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

1/0/10

Lab# 2252

**Customer**      *American Pools Management*  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

*Facility Name:*      *Hidden Valley Manor*  
  
*Address:*      *2774 Bingham Dr.*  
                         *Upper St. Clair, PA 15241*

**Sample Collection**

*Date:*      6/15/26  
*Time:*      8:15 AM  
*Method:*      Grab

*Matrix:*      *Recreational Water*  
  
*Source Type:*      *Pool*

**Sample Final Analysis**

*Date:*      6/17/26  
*Time:*      11:30 AM  
*Analyst:*      AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/16/26              | 11:00 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/16/26              | 11:00 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/15/26              | 5:50 PM  | AS      | SM 9215B |
| Field Analysis        | Results  | Reporting limit | Date/Time            |          | Analyst | Method   |
| pH:                   | 7.6 SU   | 7.2 - 7.8 SU    | 6/15/26              | 8:15 AM  | JB      | DPD      |
| Chlorine:             | 3.0 mg/l | 1.0 - 5.0 mg/l  | 6/15/26              | 8:15 AM  | JB      | DPD      |
| Turbidity:            | 1 NTU    | 1 - 2 NTU       | 6/15/26              | 8:15 AM  | JB      | Visual   |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor