Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
W-1

Lab# 008

Customer		***Sample Collection***	
Facility Name:	*Allegheny Valley School Ingram*	*Date:*	*10/27/26*
		Time:	4:10 PM
Address:	*315 W. Prospect Ave.*	*Method:*	*Grab*
	Pittsburgh, PA 15205		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*10/30/26*
		Time:	*11:00 AM*
Source Type:	*Pool*	*Analyst:*	*JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/28/26	10:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/28/26	10:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/27/26	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/27/26	4:10 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/27/26	4:10 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/27/26	4:10 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor