Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 023

Customer

Facility Name: *Bethel Park High School*

Address: *309 Church Rd.*
Bethel Park, PA 15102

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *10/26/26*
Time: 1:28 PM
Method: *Grab*

Sample Final Analysis

Date: *10/29/26*
Time: *10:00 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/27/26	9:55 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/27/26	9:55 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/26/26	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/26/26	1:28 PM	MM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	10/26/26	1:28 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/26/26	1:28 PM	MM	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)