# Dream Pools and Spas
# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

**Lab ID No. 02-04041**

**N-2**

***Lab# 346***

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *Woodlands Camp* | *Date:* | *10/26/26* |
| | | *Time:* | 10:15 AM |
| *Address:* | *134 Shenot Road* | *Method:* | *Grab* |
| | *Wexford, PA 15090* | | |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *10/29/26* |
| | | *Time:* | *9:30 AM* |
| *Source Type:* | *Pool* | *Analyst:* | *JC* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 10/27/26 | 9:25 AM | MH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 10/27/26 | 9:25 AM | MH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 10/26/26 | 4:39 PM | MH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 10/26/26 | 10:15 AM | VH | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 10/26/26 | 10:15 AM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 10/26/26 | 10:15 AM | VH | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)