Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Service Lab ID No. 02-04041

Service Lab# *425*

Laboratory Analysis Report

Facility Name:	*Chatham University*	***Sample Collection***	
		Date:	*10/27/26*
		Time:	2:25 PM
Address:	*1 Woodland Rd.*	*Method:*	*Grab*
	Pittsburgh, PA 15232		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*10/30/26*
		Time:	*10:00 AM*
Source Type:	*Pool Shallow*	*Analyst:*	*JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/28/26	9:55 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/28/26	9:55 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/27/26	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/27/26	2:25 PM	JT	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	10/27/26	2:25 PM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/27/26	2:25 PM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor