Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-3

Lab# 447

Customer

Facility Name: *Fox Chapel High School*

Address: *611 Field Club Rd*
Pittsburgh, PA 15238

Matrix: *Recreational Water*

Source Type: *Deep End*

Sample Collection

Date: *10/28/26*
Time: 10:30 AM
Method: *Grab*

Sample Final Analysis

Date: *10/30/26*
Time: *5:00 PM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/28/26	4:40 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/28/26	4:40 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/28/26	4:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	10/28/26	10:30 AM	MH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	10/28/26	10:30 AM	MH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/28/26	10:30 AM	MH	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)