Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

N - 1

Laboratory Analysis Report

Lab# *154*

Customer

Facility Name: *Hilton Garden Inn*

Address: *2000 Garden View*
Cranberry, PA 16066

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *10/27/26*
Time: 7:46 AM
Method: *Grab*

Sample Final Analysis

Date: *10/30/26*
Time: *10:30 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/28/26	10:25 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/28/26	10:25 AM	JC	SM 9222B
Standard plate count:	5700/ml	200/ml	10/27/26	5:30 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	10/28/26	11:00 AM	JC	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/27/26	7:46 AM	MM	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	10/27/26	7:46 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/27/26	7:46 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor