

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

S-2

Laboratory Analysis Report

Lab# *148*

Customer		***Sample Collection***	
Facility Name:	*Hilton Garden Inn*	*Date:*	*10/26/26*
		Time:	1:25 PM
Address:	*Synergy Dr.*	*Method:*	*Grab*
	Uniontown, PA 15401		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*10/29/26*
		Time:	*10:00 AM*
Source Type:	*Pool*	*Analyst:*	*JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/27/26	9:55 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/27/26	9:55 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/26/26	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	10/26/26	1:25 PM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	10/26/26	1:25 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/26/26	1:25 PM	SH	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)