# Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

**S-2**

***Lab# 149***

***Customer***

*Facility Name:* *Hilton Garden Inn*

*Address:* *Synergy Dr.*
*Uniontown, PA 15401*

*Matrix:* *Recreational Water*

*Source Type:* *Spa*

***Sample Collection***

*Date:* *10/26/26*
*Time:* 1:25 PM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *10/29/26*
*Time:* *10:00 AM*
*Analyst:* *JC*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 10/27/26 | 9:55 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 10/27/26 | 9:55 AM | JC | SM 9222B |
| Standard plate count: | 100/ml | 200/ml | 10/26/26 | 5:30 PM | AS | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Fecal Streptococcus | 0/100mls | 2/100mls | 10/27/26 | 10:30 AM | MH | SM 9230C |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 6.8 SU | 7.2 - 7.8 SU | 10/26/26 | 1:25 PM | SH | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 10/26/26 | 1:25 PM | SH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 10/26/26 | 1:25 PM | SH | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)