# Dream Pools and Spas
# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

**Lab ID No. 02-04041**

**C-1**

***Lab# 195***

***Customer***

*Facility Name:* *Kingley Assoc.*

*Address:* *6435 Frankstown Ave.*
*Pittsburgh, PA 15206*

*Matrix:* *Recreational Water*

*Source Type:* *Pool -Deep*

***Sample Collection***

*Date:* *10/27/26*
*Time:* 3:00 PM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *10/30/26*
*Time:* *10:00 AM*
*Analyst:* *JC*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 10/28/26 | 9:55 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 10/28/26 | 9:55 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 10/27/26 | 5:30 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 10/27/26 | 3:00 PM | JT | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 10/27/26 | 3:00 PM | JT | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 10/27/26 | 3:00 PM | JT | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor