Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 278

Customer

Facility Name: *Shaler Area Elementary School*

Address: *700 Scott Ave.*
Glenshaw, PA 15116

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *10/26/26*
Time: 1:45 PM
Method: *Grab*

Sample Final Analysis

Date: *10/29/26*
Time: *9:30 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/27/26	9:25 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/27/26	9:25 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	10/26/26	4:39 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	10/26/26	1:45 PM	VH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	10/26/26	1:45 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/26/26	1:45 PM	VH	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)