# Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
**Laboratory Analysis Report**

**Lab ID No. 02-04041**

**PPS**

***Lab# 003***

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *Allderdice H.S.* | *Date:* | *10/26/26* |
| | | *Time:* | 12:05 PM |
| *Address:* | *2409 Shady Ave.* | *Method:* | *Grab* |
| | *Pittsburgh, PA 15217* | | |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *10/29/26* |
| | | *Time:* | *9:30 AM* |
| *Source Type:* | *Pool Deep* | *Analyst:* | *JC* |

| Accredited Analysis | Results | Rating | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | A | 10/27/26 | 9:25 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | A | 10/27/26 | 9:25 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | A | 10/26/26 | 3:45 PM | MH | SM 9215B |

| Field Analysis | Results | Rating | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.6 SU | A | 10/26/26 | 12:05 PM | JT | DPD |
| Chlorine: | 3.0 mg/l | A | 10/26/26 | 12:05 PM | JT | DPD |
| Turbidity: | 1 NTU | A | 10/26/26 | 12:05 PM | JT | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor