Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
PPS
Lab# 004

Customer

Facility Name: *Allderdice H.S.*

Address: *2409 Shady Ave.*
Pittsburgh, PA 15217

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *10/26/26*
Time: 12:05 PM
Method: *Grab*

Sample Final Analysis

Date: *10/29/26*
Time: *9:30 AM*
Analyst: *JC*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	10/27/26	9:25 AM	JC	SM 9222G
Total coliforms:	0/100mls	A	10/27/26	9:25 AM	JC	SM 9222B
Standard plate count:	0/ml	A	10/26/26	3:45 PM	MH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	10/26/26	12:05 PM	JT	DPD
Chlorine:	3.0 mg/l	A	10/26/26	12:05 PM	JT	DPD
Turbidity:	1 NTU	A	10/26/26	12:05 PM	JT	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)