



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 442

Customer

Facility Name: Ridgecrest
Address: 3020 Fairport Lane
Cranberry, PA 16066

Sample Collection

Date: 5/12/26
Time: 8:50 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 5/15/26
Time: 11:00 AM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/13/26	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/13/26	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/12/26	4:51 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/12/26	8:50 AM	JMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/12/26	8:50 AM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/12/26	8:50 AM	JMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor