



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# 237

Customer

Facility Name: North Hills H.S.
Address: 53 Rochester Road
Pittsburgh, PA 15229

Sample Collection

Date: 5/6/26
Time: 8:54 AM
Method: Grab

Matrix: Recreational Water

Source Type: Shallow End

Sample Final Analysis

Date: 5/8/26
Time: 5:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/6/26	5:15 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/6/26	5:15 PM	AS	SM 9222B
Standard plate count:	100/ml	200/ml	5/6/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/6/26	8:54 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/6/26	8:54 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/6/26	8:54 AM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)