



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 2407

Customer

Facility Name: Pine Valley
Address: 504 Chapel Drive
Ellwood City, PA 16117

Sample Collection

Date: 5/5/26
Time: 2:03 PM
Method: Grab

Matrix: Recreational Water
Source Type: Slide

Sample Final Analysis

Date: 5/8/26
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/6/26	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/6/26	10:30 AM	JC	SM 9222B
Standard plate count:	40/ml	200/ml	5/5/26	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	5/5/26	2:03 PM	JMH	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	5/5/26	2:03 PM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/5/26	2:03 PM	JMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor