



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2673

Customer

Facility Name: Traditions of America

Address: 507 Rochester Rd.
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 5/11/26

Time: 12:15 PM

Method: Grab

Sample Final Analysis

Date: 5/14/26

Time: 10:30 AM

Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/12/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/12/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/11/26	5:07 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/11/26	12:15 PM	SH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/11/26	12:15 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/11/26	12:15 PM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)