



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206# 425
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

Facility Name: Chatham University
Address: 1 Woodland Rd.
Pittsburgh, PA 15232

Matrix: Recreational Water
Source Type: Pool Shallow

Sample Collection

Date: 9/14/26
Time: 2:40 PM
Method: Grab

Sample Final Analysis

Date: 9/17/26
Time: 10:00 AM
Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/15/26	9:35 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/15/26	9:35 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/14/26	4:41 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/14/26	2:40 PM	JR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/14/26	2:40 PM	JR	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/14/26	2:40 PM	JR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor