



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-3

Lab# 477

Customer

Facility Name: *Comfort Inn Duncansville*

Address: *130 Patchway Rd.
Duncansville, PA 16635*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *9/16/26*

Time: *12:34 PM*

Method: *Grab*

Sample Final Analysis

Date: *9/18/26*

Time: *5:30 PM*

Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/16/26	5:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/16/26	5:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/16/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	9/16/26	12:34 PM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/16/26	12:34 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/16/26	12:34 PM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)