



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 075

Customer

Facility Name: Courtyard by Marriott
Address: 1800 Tanger Blvd.
Washington, PA 15301

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/15/26
Time: 11:38 AM
Method: Grab

Sample Final Analysis

Date: 9/18/26
Time: 10:00 AM
Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/16/26	9:45 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/16/26	9:45 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/15/26	5:40 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/15/26	11:38 AM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/15/26	11:38 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/15/26	11:38 AM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)