



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 091

Customer

Facility Name: Doubletree Hotel
Address: 101 Doubletree Dr.
Pittsburgh, PA 15205

Sample Collection

Date: 9/15/26
Time: 8:59 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 9/18/26
Time: 10:30 AM
Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/16/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/16/26	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/15/26	6:20 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	9/15/26	8:59 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/15/26	8:59 AM	MM	DPD
Turbidity:	2 NTU	1 - 2 NTU	9/15/26	8:59 AM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)