



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
C-2

Lab# 377

Customer

Facility Name: Drury Hotel
Address: 745 Grant St.
Pittsburgh, PA 15219

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 9/14/26
Time: 11:45 AM
Method: Grab

Sample Final Analysis

Date: 9/17/26
Time: 11:00 AM
Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	9/15/26 10:45 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/15/26 10:45 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/14/26 5:27 PM	JC	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	9/15/26 12:12 PM	AH	SM 9230C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.0 SU	7.2 - 7.8 SU	9/14/26 11:45 AM	EG	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/14/26 11:45 AM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/14/26 11:45 AM	EG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)