



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-2**

**Lab# 410**

**Customer**

**Facility Name:** *Fairfield Inn Airport*

**Address:** *1004 Sutherland Dr  
Pittsburgh, PA 15205*

**Matrix:** *Recreational Water*

**Source Type:** *Pool*

**Sample Collection**

**Date:** *9/14/26*

**Time:** *1:12 PM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *9/17/26*

**Time:** *10:30 AM*

**Analyst:** *JC*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 9/15/26              | 10:10 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 9/15/26              | 10:10 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 9/14/26              | 5:17 PM  | JC      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 8.0 SU   | 7.2 - 7.8 SU    | 9/14/26   | 1:12 PM | MH      | DPD    |
| Chlorine:      | 7.5 mg/l | 1.0 - 5.0 mg/l  | 9/14/26   | 1:12 PM | MH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 9/14/26   | 1:12 PM | MH      | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)