



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

N - 1

Laboratory Analysis Report Lab# 154

Customer

Facility Name: Hilton Garden Inn
Address: 2000 Garden View
Cranberry, PA 16066

Sample Collection

Date: 9/14/26
Time: 9:05 AM
Method: Grab

Matrix: Recreational Water
Source Type: Spa

Sample Final Analysis

Date: 9/17/26
Time: 11:30 AM
Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/15/26	11:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/15/26	11:20 AM	AH	SM 9222B
Standard plate count:	150/ml	200/ml	9/14/26	5:37 PM	JC	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	9/15/26	12:12 PM	AH	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/14/26	9:05 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/14/26	9:05 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/14/26	9:05 AM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)