



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 162

Customer

Facility Name: *Holiday Inn Express*

Address: *3695 State Route 31*
Donegal, PA 15628

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *9/14/26*

Time: *9:57 AM*

Method: *Grab*

Sample Final Analysis

Date: *9/17/26*

Time: *9:30 AM*

Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/15/26	9:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/15/26	9:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/14/26	4:08 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/14/26	9:57 AM	JC	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/14/26	9:57 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/14/26	9:57 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor