



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-2**

**Lab# 163**

**Customer**

**Facility Name:** Holiday Inn Express

**Address:** 3695 State Route 31  
Donegal, PA 15628

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 9/14/26

**Time:** 9:57 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 9/17/26

**Time:** 9:30 AM

**Analyst:** JC

| Accredited Analysis   | Results   | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|-----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent    | Absent          | 9/15/26              | 9:00 AM  | AH      | SM 9222G |
| Total coliforms:      | 0/100mls  | 2/100mls        | 9/15/26              | 9:00 AM  | AH      | SM 9222B |
| Standard plate count: | 0/ml      | 200/ml          | 9/14/26              | 4:08 PM  | AH      | SM 9215B |
| Additional Analysis   | Results   | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
| Fecal Streptococcus   | 0/100mls  | 2/100mls        | 9/15/26              | 12:12 PM | AH      | SM 9230C |
| Field Analysis        | Results   | Reporting limit | Date/Time            |          | Analyst | Method   |
| pH:                   | 8.0 SU    | 7.2 - 7.8 SU    | 9/14/26              | 9:57 AM  | JC      | DPD      |
| Chlorine:             | 10.0 mg/l | 1.0 - 5.0 mg/l  | 9/14/26              | 9:57 AM  | JC      | DPD      |
| Turbidity:            | 1 NTU     | 1 - 2 NTU       | 9/14/26              | 9:57 AM  | JC      | Visual   |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)