



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 175

Customer

Facility Name: Hyatt House

Address: 2795 South Water St.
Pittsburgh, PA 15603

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/14/26

Time: 4:44 PM

Method: Grab

Sample Final Analysis

Date: 9/17/26

Time: 11:00 AM

Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/15/26	10:45 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/15/26	10:45 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/14/26	5:27 PM	JC	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/14/26	4:44 PM	EG	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/14/26	4:44 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/14/26	4:44 PM	EG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)