



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 183

Customer

Facility Name: Imperial House
Address: 5600 Munhall Rd.
Pittsburgh, PA 15217

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/15/26
Time: 12:37 PM
Method: Grab

Sample Final Analysis

Date: 9/18/26
Time: 9:00 AM
Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/16/26 8:55 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/16/26 8:55 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/15/26 3:40 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/15/26 12:37 PM	JT	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/15/26 12:37 PM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/15/26 12:37 PM	JT	Visual

Sample comments

Andre Smith, Lead Supervisor

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)