



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 220

Customer

Facility Name: Masonic Village

Address: 1000 Masonic Dr.
Sewickley, PA 15143

Sample Collection

Date: 9/14/26
Time: 11:01 AM
Method: Grab

Sample Final Analysis

Date: 9/17/26
Time: 11:00 AM
Analyst: JC

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/15/26	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/15/26	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/14/26	6:00 PM	JC	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/14/26	11:01 AM	AMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/14/26	11:01 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/14/26	11:01 AM	AMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor