



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-2**

**Lab# 296**

**Customer**

**Facility Name:** Steel Valley High School

**Address:** 3113 Main Street  
Munhall, PA 15120

**Matrix:** Recreational Water

**Source Type:** Pool Deep

**Sample Collection**

**Date:** 9/14/26

**Time:** 8:40 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 9/17/26

**Time:** 10:00 AM

**Analyst:** JC

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 9/15/26              | 9:35 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 9/15/26              | 9:35 AM | AH      | SM 9222B |
| Standard plate count: | 50/ml    | 200/ml          | 9/14/26              | 4:41 PM | AH      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 8.2 SU   | 7.2 - 7.8 SU    | 9/14/26   | 8:40 AM | SH      | DPD    |
| Chlorine:      | 0.0 mg/l | 1.0 - 5.0 mg/l  | 9/14/26   | 8:40 AM | SH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 9/14/26   | 8:40 AM | SH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor