



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-3

Lab# 474

Customer

Facility Name: Summit Athletic Club

Address: 2900 Plank Rd.
Altoona, PA 16601

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 9/16/26

Time: 1:08 PM

Method: Grab

Sample Final Analysis

Date: 9/18/26

Time: 5:30 PM

Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/16/26	5:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/16/26	5:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/16/26	5:00 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	9/16/26	5:00 PM	SL	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	9/16/26	1:08 PM	SL	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	9/16/26	1:08 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/16/26	1:08 PM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)