



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 306

Customer

Facility Name: University of Pittsburgh

Address: 3501 Allequippa St.
Pittsburgh, PA 15260

Matrix: Recreational Water

Source Type: Sm Pool Deep

Sample Collection

Date: 9/15/26

Time: 10:46 AM

Method: Grab

Sample Final Analysis

Date: 9/18/26

Time: 9:30 AM

Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/16/26	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/16/26	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/15/26	4:50 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/15/26	10:46 AM	JT	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/15/26	10:46 AM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/15/26	10:46 AM	JT	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor