



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 367

Customer

Facility Name: YMCA - Uniontown

Address: 1 Ymca Lane
Uniontown, PA 15401

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/14/26
Time: 12:35 PM
Method: Grab

Sample Final Analysis

Date: 9/17/26
Time: 10:30 AM
Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/15/26	10:10 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/15/26	10:10 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/14/26	5:17 PM	JC	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/14/26	12:35 PM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/14/26	12:35 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/14/26	12:35 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor