



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 026

Customer

Facility Name: *Brashear High School*

Address: *590 Crane Ave
Pittsburgh, PA 15216*

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *9/14/26*

Time: *9:37 AM*

Method: *Grab*

Sample Final Analysis

Date: *9/17/26*

Time: *9:30 AM*

Analyst: *JC*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	9/15/26	9:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	9/15/26	9:00 AM	AH	SM 9222B
Standard plate count:	0/ml	A	9/14/26	4:08 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	9/14/26	9:37 AM	JT	DPD
Chlorine:	3.0 mg/l	A	9/14/26	9:37 AM	JT	DPD
Turbidity:	1 NTU	A	9/14/26	9:37 AM	JT	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)