Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
W-1

Lab# 020

Customer

Facility Name: Beaver Area High School

Address: Gypsy Glen
Beaver, PA 15009

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 10/13/26
Time: 10:40 AM
Method: Grab

Sample Final Analysis

Date: 10/16/26
Time: 11:00 AM
Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/14/26	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/14/26	10:30 AM	JC	SM 9222B
Standard plate count:	570/ml	200/ml	10/13/26	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	10/13/26	10:40 AM	SL	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	10/13/26	10:40 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/13/26	10:40 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor