Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
C-2

Lab# 032

Customer

Facility Name: *Cambria Suites*

Address: *1320 Centre Ave*
Pittsburgh, PA 15219

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *10/12/26*
Time: 12:45 PM
Method: *Grab*

Sample Final Analysis

Date: *10/15/26*
Time: *10:30 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/13/26	10:10 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/13/26	10:10 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	10/12/26	5:10 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	10/13/26	10:50 AM	JC	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	10/12/26	12:45 PM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	10/12/26	12:45 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/12/26	12:45 PM	SL	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)