Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
C-1

Lab# 042

Customer

Facility Name: *Carnegie Mellon*

Address: *5000 Forbes Ave.*
Pittsburgh, PA 15213

Matrix: *Recreational Water*

Source Type: *Lap pool Deep*

Sample Collection

Date: *9/29/26*
Time: 9:15 AM
Method: *Grab*

Sample Final Analysis

Date: *10/2/26*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/30/26	8:55 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/30/26	8:55 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	2:45 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/29/26	9:15 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/29/26	9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/29/26	9:15 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Andre Smith, Lead Supervisor