Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 043

Customer

Facility Name: *Carnegie Mellon*

Address: *5000 Forbes Ave.*
Pittsburgh, PA 15213

Matrix: *Recreational Water*

Source Type: *Dive pool - shallow*

Sample Collection

Date: *8/25/26*
Time: 8:44 AM
Method: *Grab*

Sample Final Analysis

Date: *8/28/26*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/26/26	10:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/26/26	10:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/25/26	4:55 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/25/26	8:44 AM	JT	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/25/26	8:44 AM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/25/26	8:44 AM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor