Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 390

Customer		***Sample Collection***	
Facility Name:	*Fairfield Inn & Suites*	*Date:*	*9/9/26*
		Time:	3:16 PM
Address:	*1000 University Parkway*	*Method:*	*Grab*
	Slippery Rock, PA 16057		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*9/12/26*
		Time:	*9:30 AM*
Source Type:	*Spa*	*Analyst:*	*JC*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	9/10/26	9:25 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/10/26	9:25 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/9/26	6:30 PM	JC	SM 9215B

Additional Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9230C

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	7.6 SU	7.2 - 7.8 SU	9/9/26	3:16 PM	MM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/9/26	3:16 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/9/26	3:16 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor