Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# ***2201***

Customer		***Sample Collection***	
Facility Name:	*Fox Chapel Golf Club*	*Date:*	*8/24/26*
		Time:	10:52 AM
Address:	*426 Fox Chapel Road*	*Method:*	*Grab*
	Pittsburgh, PA 15238-2298		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*8/27/26*
		Time:	*10:00 AM*
Source Type:	*Shallow End*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/25/26	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/25/26	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/24/26	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/24/26	10:52 AM	BG	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/24/26	10:52 AM	BG	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/24/26	10:52 AM	BG	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor