Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2784

Customer

Facility Name: *Franklin Ridge Estates*

Address: *1624 Country Club Dr.*
Pittsburgh, PA 15219

Matrix: *Recreational Water*

Source Type: *Baby Pool*

Sample Collection

Date: *8/27/26*
Time: 2:20 PM
Method: *Grab*

Sample Final Analysis

Date: *8/29/26*
Time: *5:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/26	4:40 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/26	4:40 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/27/26	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/27/26	2:20 PM	EG	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/27/26	2:20 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/27/26	2:20 PM	EG	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)