Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 117

Customer

Facility Name: *Hampton Inn*

Address: *1247 Smallman St.*
Pittsburgh, PA 15222

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *9/1/26*
Time: 1:25 PM
Method: *Grab*

Sample Final Analysis

Date: *9/4/26*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/2/26	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/2/26	9:30 AM	AS	SM 9222B
Standard plate count:	60/ml	200/ml	9/1/26	5:00 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	9/2/26	12:00 PM	AS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	9/1/26	1:25 PM	MB	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/1/26	1:25 PM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/1/26	1:25 PM	MB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor