Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N - 1

Lab# 486

Customer

Facility Name: *Hampton Inn Suites Mercer*

Address: *4 Holiday Blvd*
Mercer, PA 16137

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *10/13/26*
Time: 12:38 PM
Method: *Grab*

Sample Final Analysis

Date: *10/16/26*
Time: *10:00 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/14/26	9:55 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/14/26	9:55 AM	MH	SM 9222B
Standard plate count:	100/ml	200/ml	10/13/26	5:34 PM	MH	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	10/14/26	10:20 AM	MH	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/13/26	12:38 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/13/26	12:38 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/13/26	12:38 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor