Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 147

Customer		***Sample Collection***	
Facility Name:	*Highland High School*	*Date:*	*9/29/26*
		Time:	11:36 AM
Address:	*1500 Pacific Ave.*	*Method:*	*Grab*
	Natrona Heights, PA 15065		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*10/2/26*
		Time:	*9:30 AM*
Source Type:	*Pool Shallow*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/30/26	9:25 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/30/26	9:25 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/29/26	5:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/29/26	11:36 AM	AMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/29/26	11:36 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/29/26	11:36 AM	AMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor