Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis ~~Report~~

Lab ID No. 02-04041

N - 1

Lab# ***164***

Customer		***Sample Collection***	
Facility Name:	*Holiday Inn Express - Butler*	*Date:*	*9/23/26*
		Time:	9:15 AM
Address:	*203 North Duffy Rd* *Butler, PA 16001*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*9/26/26*
		Time:	*10:30 AM*
Source Type:	*Pool*	*Analyst:*	*JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/24/26	10:00 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/24/26	10:00 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	9/23/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/23/26	9:15 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/23/26	9:15 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/23/26	9:15 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor